



Electrically insulating gloves made from non-conductive natural rubber Combines high dielectric and physical strength to offer excellent electrical resistance. Certified to EN60903, they offer the highest level of electrical protection available. Every pair is electrically tested prior to release for sale. No gloves of classes 1, 2, 3 and 4 should be used unless they have been tested within a maximum period of six months.

Electrical insulation: EN 60903 classe 4

POLYCO Glove Electricians class 4



Characteristics

Series: Electricians Gloves™ Type: Electrically Insulating

Length: 410 mm Thickness: 3.6 mm Colour: Natural colour

Coating Colour: Natural colour

Liner Material: Latex Cuff Style: Safety cuff Material: Latex

For nominal voltage up to: 36000 V

Disclaimer: The content of this document has been composed with the utmost care. However, it is possible that certain information changes over time, becomes inaccurate or incomplete. ERIKS does not guarantee that the information provided on this document is up to date, accurate and complete; the information provided is not intended to be advice. ERIKS shall never be liable for damage resulting from the use of the information provided.

PR_EC002099_0036_JLR_EN_25.04.2024